

CERTIFICATE

Issued to:
Applicant:
Cabur S.r.l.
Località Isolagrande 45
17041, Altare (SV), Italy

Manufacturer/Licensee:
Cabur S.r.l.
Località Isolagrande 45
17041, Altare (SV), Italy

Product(s) : fuse-terminal block
Trade name(s) : CABUR
Type(s)/model(s) : HFR.4

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-3:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 17 January 2011 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2139097.04

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product : fuse-terminal block
trade name(s) : CABUR
type(s) : HFR.4
material : thermoplastic material
method of fixing : top hat rail 35 mm (EN 50022)

Additional information**Markings**

Trademark, type designation and complete electrical ratings are indented in the insulation material.

Product data - type HFR.4

rated voltage : rated insulation voltage 500 V and working voltage determined by the fuselink max. 250 V
current : 10 A
rated impulse withstand voltage : 4 kV
rated connecting capacity : 4 mm²
connectable conductors : 0,2 mm² - 6 mm² rigid and flexible
fuse size : 6,3 x 32 mm
description : fuse terminal block with screwless-type terminals, 1-pole with 2 clamping units per pole
overload and short circuit protection
separate arrangement: Pv 2,5 W / 2,5 A
compound arrangement: Pv 1,6 W / 1,0 A

exclusive short-circuit protection
separate arrangement: PVK 4 W / 10 A
compound arrangement: PVK 2,5 W / 2,5 A

TESTS**Test requirements**

EN 60947-7-3:2009

Test result


The test results are laid down in DEKRA test file 2139097.04.

Conclusion

The examination proved that all test requirements were met.

Tested by : W.C. van Ginkel

Checked by : H.L. Schendstok



C.C. Burger

Factory locations

Cabur S.r.l.
Località Isolagrande 45, 17041, Altare (SV)
Italy