

CERTIFICATE

Issued to:
Applicant:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Manufacturer/Licensee:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Product(s) : terminal blocks
Trade name(s) : CABUR
Type(s)/model(s) : RN.2/4

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 14 February 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.05

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: terminal blocks
trade name(s)	: CABUR
type(s)	: RN.2/4
material	: thermoplastic material

Product data - type RN.2/4

rated insulation voltage	: 500 V
rated impulse withstand voltage	: 8 kV
conventional free air thermal current	: 24 A
rated cross-section	: 2,5 mm ²
rated connecting capacity	: 0,2 mm ² - 4 mm ² rigid and flexible
torque clamping unit	: 0,4 Nm
method of mounting	: top hat rail 15 mm
description	: terminal block with screw-type clamping units, 1-pole, with 2 clamping units per pole.

TESTS**Test requirements**

EN 60947-7-1:2009

Test result

The test results are laid down in DEKRA test file 2196527.05.

Remarks

On request of the manufacturer additional temperature-rise test is carried out for a maximum current of 30 A.

This certificate replaces certificate 2026517.01 issued on 1 April 2003.


Conclusion

The examination proved that all test requirements were met.

Tested by : A.A.P.M. van Vught

A blue ink signature of A.A.P.M. van Vught, consisting of a stylized 'A' and 'V' with a horizontal line through them.

Checked by : F.S. Strikwerda

A blue ink signature of F.S. Strikwerda, featuring a stylized 'F' and 'S' with a horizontal line through them.

Factory locations

Cabur s.r.l.

Località Isolagrande 45, 17041, Altare (SV)

Italy