

# CERTIFICATE

Issued to:  
Applicant:  
**Cabur s.r.l.**  
**Località Isolagrande 45**  
**17041 Altare (SV), Italy**

Manufacturer/Licensee:  
**Cabur s.r.l.**  
**Località Isolagrande 45**  
**17041 Altare (SV), Italy**

Product(s) : terminal blocks  
Trade name(s) : CABUR  
Type(s)/model(s) : RN.1

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 19 December 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.06

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product : terminal blocks  
trade name(s) : CABUR  
type(s) : RN.1  
material : thermoplastic material

**Product data - type RN.1**

rated insulation voltage : 500 V  
rated impulse withstand voltage : 6 kV  
conventional free air thermal current : 17,5 A  
rated cross-section : 1,5 mm<sup>2</sup>  
rated connecting capacity : 0,5 mm<sup>2</sup> - 1,5 mm<sup>2</sup> rigid and flexible  
torque clamping unit : 0,4 Nm  
method of mounting : top hat rail 15 mm  
description : terminal block with screw-type clamping units, 1-pole, with 2 clamping units per pole.

**TESTS****Test requirements**

EN 60947-7-1:2009

**Test result**

The test results are laid down in DEKRA test file 2196527.06.

**Remarks**

This certificate replaces certificate 95.4012.14 issued 25 July 1996.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : A.A.P.M. van Vught

  


Checked by : F.S. Strikwerda

**Factory locations**

Cabur s.r.l.

Località Isolagrande 45, 17041, Altare (SV)

Italy