

# CERTIFICATE

Issued to:  
Applicant:  
**Cabur s.r.l.**  
**Località Isolagrande 45**  
**17041 Altare (SV), Italy**

Manufacturer/Licensee:  
**Cabur s.r.l.**  
**Località Isolagrande 45**  
**17041 Altare (SV), Italy**

Product(s) : terminal blocks  
Trade name(s) : CABUR  
Type(s)/model(s) : TEO.4, TED.4

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-2:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 24 April 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.19

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	: terminal blocks
trade name(s)	: CABUR
type(s)	: TEO.4, TED.4
material	: thermoplastic material

**Product data - type TEO.4**

rated cross-section	: 4 mm <sup>2</sup>
rated connecting capacity	: 0,2 mm <sup>2</sup> - 6 mm <sup>2</sup> flexible 0,2 mm <sup>2</sup> - 6 mm <sup>2</sup> rigid
function	: PE
torque clamping unit	: 0,5 Nm
method of mounting	: top hat rail 35 mm
description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole.

**Product data - type TED.4**

rated cross-section	: 4 mm <sup>2</sup>
rated connecting capacity	: 0,2 mm <sup>2</sup> - 6 mm <sup>2</sup> flexible 0,2 mm <sup>2</sup> - 6 mm <sup>2</sup> rigid
function	: PE
torque clamping unit	: 0,5 Nm
method of mounting	: G-profile 32 mm
description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole.

**TESTS****Test requirements**

EN 60947-7-2:2009

**Test result**

The test results are laid down in DEKRA test file 2196527.19.

**Remarks**

This certificate replaces certificate 2079868.02 and 2079868.03 issued 22 September 2005.


**Conclusion**

The examination proved that all test requirements were met.

Tested by : A.A.P.M. van Vught

A blue ink signature of A.A.P.M. van Vught, featuring a large, stylized 'V' and 'A'.

Checked by : F.S. Strikwerda

A blue ink signature of F.S. Strikwerda, featuring a stylized 'S' and 'F'.

**Factory locations**

Cabur s.r.l.

Località Isolagrande 45, 17041, Altare (SV)

Italy