

CERTIFICATE

Issued to:
Applicant:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Manufacturer/Licensee:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Product : protective conductor terminal block
Trade name(s) : CABUR
Type(s)/model(s) : TE.16/D and TE.16/O

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-2:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 30 May 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.27

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: protective conductor terminal block
Trade name(s)	: CABUR
Type(s)/model(s)	: TE.16/D and TE.16/O
Material	: thermoplastic material

Product data – type TE.16/D

Rated cross-section	: 16 mm ²
Rated connecting capacity	: 0,5 mm ² - 16 mm ² flexible 0,5 mm ² - 25 mm ² rigid
Function	: PEN
Torque clamping unit	: 1,8 Nm
Torque clamp to support	: 1,2 Nm
Method of mounting	: G-profile 32 mm
Description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole

Product data – type TE.16/O

Rated cross-section	: 16 mm ²
Rated connecting capacity	: 0,5 mm ² - 16 mm ² flexible 0,5 mm ² - 25 mm ² rigid
Function	: PEN
Torque clamping unit	: 1,8 Nm
Torque clamp to support	: 1,2 Nm
Method of mounting	: top hat rail 35 mm
Description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole

TESTS**Test requirements**

EN 60947-7-2:2009

Test result

The test results are laid down in DEKRA test file 219652700.

Additional Information

This certificate replaces certificate 95.4012.08 issued 30 May 1996.

Conclusion

The examination proved that all requirements were met.

Factory location

Cabur s.r.l.

Località Isolagrande 45

17041 Altare (SV), Italy