

CERTIFICATE

KEMA No.: 2017373.01

Issued to:
Applicant:
Cabur s.r.l.

**Via Delle Industrie, 129
ALBISSOLA MARINA, ITALY**

Manufacturer/Licensee:
Cabur s.r.l.

**Via Delle Industrie, 129
ALBISSOLA MARINA, ITALY**

Product : terminal blocks
Trade name : CABUR
Types/models : TE.50/O and TE.50/D

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-2:1995
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012.

KEMA hereby grants the right to use the KEMA-KEUR certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: March 28, 2002

L.J.W. van Megen
Certification Manager

© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	terminal blocks
trade name	:	CABUR
types	:	TE.50/D, TE.50/O
material	:	thermoplastic material

Additional information

Markings: Trademark, type designation (TE.50/D-TE.50/O) and rated connecting capacity are indented in the thermoplastic material.

Product data – type TE.50/D

rated connecting capacity	:	50 mm ²
connectable conductors	:	1,5 mm ² - 50 mm ² flexible 1,0 mm ² - 70 mm ² rigid
description	:	protective conductor terminal block, 1 - pole with screw-type terminals, 2 clamping units per pole, for mounting on G - profile rail 32 mm (EN 50035)

Product data – type TE.50/O

rated connecting capacity	:	50 mm ²
connectable conductors	:	1,5 mm ² - 50 mm ² flexible 1,0 mm ² - 70 mm ² rigid
description	:	protective conductor terminal block, 1 - pole with screw-type terminals, 2 clamping units per pole, for mounting on top hat rail 35 mm (EN 50022)

TESTS**Test requirements**

- EN 60947-7-2:1995 + C:1996-01

Test result

The test results are laid down in KEMA test file no. 2017373.01.

KEMA Quality B.V.

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 5185, 6802 ED Arnhem, The Netherlands
Telephone +31 26 3 56 20 00, Telefax +31 26 3 52 58 00

Conclusion

The examination proved that all test requirements were met.

Tested by : W.C. van Ginkel 

Checked by : H.L. Schendstok 

Factory-Location

Cabur s.r.l.,
Via Delle Industrie, 129, Albissola Marina, Italy