

CERTIFICATE

Issued to:
Applicant:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Licensee:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Product : Protective conductor terminal blocks for copper conductors
Trade name(s) : CABUR
Type(s)/model(s) : TR.2

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-2:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 14 March 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.25

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Theresa Fleskes
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Protective conductor terminal blocks for copper conductors
Trade name(s)	: CABUR
Type(s)/model(s)	: TR.2
Material	: thermoplastic material
Rated cross-section	: 2,5 mm ²
Rated connecting capacity	: 0,2 mm ² - 4 mm ² rigid and flexible
Function	: PE
Torque clamping unit	: 0,4 Nm
Method of mounting	: top hat rail 15 mm
Description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole.

TESTS**Test requirements**

EN 60947-7-2:2009

Test result

The test results are laid down in DEKRA test file 219652700.

Additional information

This certificate replaces certificate 2031162.02 issued 30 September 2003.

Conclusion

The examination proved that all requirements were met.

Factory location

Cabur s.r.l.

Località Isolagrande 45

17041 Altare (SV), Italy