

CERTIFICATE

Issued to:
Applicant:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Manufacturer/Licensee:
Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy

Product : protective conductor terminal blocks for copper conductors
Trade name(s) : CABUR
Type(s)/model(s) : TR.4

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-2:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 954012

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 13 September 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2196527.09

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: protective conductor terminal blocks for copper conductors
Trade name(s)	: CABUR
Type(s)/model(s)	: TR.4
Material	: thermoplastic material

Product data – type TR.4

Rated cross-section	: 4 mm ²
Rated connecting capacity	: 0,2 mm ² - 6 mm ² rigid and flexible
Function	: PE
Torque clamping unit	: 0,5 Nm
Method of mounting	: top hat rail 15 mm
Description	: protective conductor terminal block with screw-type clamping units, 1 pole, 2 clamping units per pole

TESTS**Test requirements**

EN 60947-7-2:2009

Test result

The test results are laid down in DEKRA test file 219652700.

Additional Information

This certificate replaces type TR.4 in certificate 2076103.01 issued 1 December 2004.

Conclusion

The examination proved that all requirements were met.

Factory location

Cabur s.r.l.
Località Isolagrande 45
17041 Altare (SV), Italy