

### Camignone di Passirano 28/03/2018

### DECLARATION OF PERFORMANCE No. DoP 00011

## Unique identification code of the product-type

- · H07V-K 1x1,5 mm<sup>2</sup>
- H07V-K 1x2.5 mm²
- H07V-K 1x4,0 mm<sup>2</sup>
- · H07V-K 1x6,0 mm<sup>2</sup>

### Intended use

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

#### **Producer**

Elettro Brescia S.p.A. Via Bulloni 36 I – 25050 Camignone di Passirano (BS)

# **AVCP SYSTEM**

3

### **Harmonized Standard**

EN 50575:2014 + A1:2016

### **Notified Body**

1008 - TÜV Rheinland InterCert Muszaki Felügyeleti és Tanúsító Korlátolt Felelosségu Társaság

## Agent

N.A.

### **Declared performance**

Fire Reaction: Eca

Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno Quality and Laboratory Manager

Loron Solbrum