

## Camignone di Passirano 28/03/2018

# DECLARATION OF PERFORMANCE No. DoP 00009

# Unique identification code of the product-type

H05V2V2-F 3G0,75 mm²
H05V2V2-F 4G0,75 mm²
H05V2V2-F 3G1,0 mm²
H05V2V2-F 4G1,0 mm²
H05V2V2-F 3G1,5 mm²
H05V2V2-F 4G1,5 mm²
H05V2V2-F 3G2,5 mm²
H05V2V2-F 4G2,5 mm²
H05V2V2-F 5G2,5 mm²

#### Intended use

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

#### **Producer**

Elettro Brescia S.p.A. Via Bulloni 36 I – 25050 Camignone di Passirano (BS)

# **AVCP SYSTEM**

3

#### **Harmonized Standard**

EN 50575:2014 + A1:2016

## **Notified Body**

1008 – TÜV Rheinland InterCert Muszaki Felügyeleti és Tanúsító Korlátolt Felelosségu Társaság

# Agent

N.A.

## **Declared performance**

Fire Reaction: Eca

Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno

Quality and Laboratory Manager

War Id brun